

In many cases, several sensors are connected together to control the same fixture, or to trigger on each other, the sudden on/off may cause huge magnetic pulse and mis-trigger the sensor. Hytronik synchronized sensor HC419V is specially designed for these applications with 1-10V output which employes a strong software to overcome the magnetic interferences.

sensorDIM

N

1-10V output

Model: HC419V (120-277Vac)

Product Functions and Features

In a lot of buildings, there is a need that the moving object in corridor or undercover garage can trigger a transmitter luminaire with connected receiver luminaries from more than one direction. Every transmitter luminaries (containing the sensor) should be able to trigger the whole installation whether it's an on/off or dimming installation.

See the example below that there are several exits /entrances to the corridor, no matter which sensor at exit /entrance is triggered, the luminaries in the group will light up.

Mechanical structure (mm)

Hold-time

-<u>Ò</u>

2~50Lux

1...10V

4 Tri-level control (corridor function)

Same as Tridonic excel control gear, Hytronik builds this function inside the motion sensor to achieve tri-level control, for some areas require a light change notice before switch-off.

It offers 3 levels of light: 100%-->dimmed light (10%, 20%, 30%, 50% optional)-->off; and 2 periods of selectable waiting time: motion hold-time and stand-by period; selectable daylight threshold and freedom of detection area.

With sufficient natural light, the light does not switch on when presence detected.



With insufficient natural light, the person comes from any direction, the group of lamps switch on.

After the hold-time, the whole group of lamps dim to pre-defined dimming level when no motion is detected.





After the stand-by period, the whole group of lamps switch off automatically.



5 Wiring diagram

1 sensor controls a group of ballast /driver



Multiple sensors control the same group of ballast /driver



Detection Pattern





Settings

Detection area

Detection area can be reduced by selecting the combination on the DIP switches to fit precisely for each specific application.



|- 100% ||- 75% |||- 50% |V- 10%

2 Hold-time

Hold-time means the time period you would like to keep the lamp on 100% after the person has left the detection area.



3 Daylight sensor

The daylight threshold can be set on DIP switches, to fit for particular application.



I – Disable II – 50Lux III – 10Lux IV – 2Lux

Stand-by period (tri-level control)

This is the time period you would like to keep at the low light output level before it is completely switched off in the long absence of people. Note: "Os" means on/off control;

"+ ∞ " means bi-level control, fixture never switches off.

Stand-by dimming level

This is the dimmed low light output level you would like to have after the hold-time in the absence of people.



I – Os II – 10s III – 1 min IV – 5 min V- 10min VI – 30min VII – 1 h V|||− +∞

	1	2		
Ι			10%	
Π		0	20%	
Ш	0		30%	
IV	\bigcirc	0	50%	1, 1, 20%

-	•	
	hnical	
IEC	IIIICU	

	Operating voltage	120-277Vac
	Switched power (Capacitive load)	Max. 400W@120Vac; 1000W@277Vac
	Stand-by power	<0.5W
	Warm time	20s
	Detection area	10/50/75/100%, can be customized
	Hold-time	5s/30s/1min/5min/10min/20min/30min
	Stand-by period	Os/10s/1min/5min/10min/30min/1h/+∞
	Stand-by dimming level	10%/20%/30%/50%
	Daylight threshold	2~50Lux, disable
	Sensor principle	HF (microwave) motion detector
	HF (microwave) frequency	5.8GHz+/-75MHz
	HF (microwave) power	<0.2mW
	Detection range	Max. (ØxH): 12m x 6m
	Detection angle	30°~150°
	Mounting height	Max. 6m
	Operating temperature	-35°C ~ +70°C
	Max. case temperature (Tc)	80°C
	IP rating	IP20
	Certificate	cULus listed, ETL, FCC