## PIR Standalone Motion Sensor with Bluetooth® NLC

HBIR29/NLC/R HBIR29/NLC/H

Low-bay Reinforced Low-bay High-bay

HBIR29/NLC/H Reinforced High-bay



#### **Product Description**

HBIR29/NLC is a Bluetooth PIR standalone motion sensor. It is ideal for typical indoor applications such as office, classroom, healthcare and other commercial areas. Meanwhile, all commissioning and settings can be done via SILVAIR app.





HBIR29/NLC

HBIR29/NLC/R







HBIR29/NLC/F (3-pyro)

### Functions and Features

- Bluetooth® NLC compliant
- Surface mount kit available as accessory
- PIR occupancy detection with 2 types of blind inserts / blanking plates
- Compact form factor
- Autonomous sensor-based control
- OTA firmware upgrade
- Individual/group addressing
- Decentralized control (no single point of failure)
- User-friendly design for installation
- High bay version available (up to 15m in height)
- 5-years warranty





# The access to Silvair apps

mobile app: Silvair on the App Store

web app: platform.silvair.com

# Technical Specifications

Bluetooth Transceiver	
Operation frequency	2.4 GHz - 2.483 GHz
Transmission power	4 dBm
Range (Typical indoor)	10~30m
Protocol	<b>₿ Bluetooth</b> ® NLC


Input & Output Characteristics		
Operating voltage	220~240VAC 50/60Hz	
Max input current	10mA	
Output	I guaranteed : 44mA I max : 80mA U rated : 12VDC	
Stand-by power	<0.65W (Empty load)	
Warming-up	5s	
Life span	50,000h@Tc=60°C	
Tc max	60°C	
Lux range	1-1,000lux Tolerance +/- 20%	

Sensor Data		
Sensor Model	PIR max* detection range	
HBIR29/NLC	Installation Height : 6m Detection Range(∅) :9m	
HBIR29/NLC/R	Installation Height : 6m Detection Range(∅) : 10m	
HBIR29/NLC/H	Installation height: 15m (forklift) 12m (person) Detection range (Ø): 24m	
hbir29/NLC/Rh	Installation height: 20m (forklift) 12m (person) Detection range (Ø): 40m	
Detection angle	360°	
Standard compliance	EN300328, EN301489-1, EN301489-17, EN62479, EN55015, EN61547, EN60669-1, EN60669-2-1, EN62493	


* For more details of	detection range	nlease refer to	"detection	nattern" section

# Environment Operation temperature Operation humidity (RH%) Storage temperature (°C) Storage humidity (RH%) IP rating IP rating (facial part) Ta: -20°C ~ +50°C 10%~90% (Non-condensing) 10%~90% (Non-condensing) IP 10%~90% (IP 10%~90%) IP

#### Mechanical Structure & Dimensions



- 1. Ceiling (drill hole Ø 66~68mm)
- 2. Carefully prise off the cable clamps.
- 3. Make connections to the pluggable terminal blocks.
- 4. Insert plug connectors and secure using the provided cable clamps, then clip terminal covers to the base.
- 5. Fit detection blind (if required) and desired lens.
- 6. Clip fascia to body.
- 7. Bend back springs and insert into ceiling.



Subject to change without notice. Edition: 11 Mar. 2025 Ver. AO Page 2/8

<sup>\*</sup>IP54 (facial part) only for lens of standard,/R,/H.










HBIR29/NLC/H


za/infc/ii HRIK5A/infc/

# Wiring Diagram



## Wire Preparation






Pluggable screw terminal. It is recommended to make connections to the terminal before fitting to the sensor.

# Supported Bluetooth Mesh Models

#### Placement Guide and Typical Range

Smart Phone to Device Range



The smart device with the App installed will have a typical range of 10m, but varies from device to device. During commissioning, the installer will need to be in range of the devices when searching for devices to add to the network.


Once the devices have been added to the network via the App, the devices will start communicating within the wireless mesh. This means that once the network is complete, all devices are accessible from the smart device when in a 20m range of a single point.

Subject to change without notice. Edition: 11 Mar. 2025 Ver. AO Page 3/8


#### Optional Accessories For Water-Proof

Big and small silicon gasket used to make IP54 degree protection (mounted into HA09 housing for ceiling mount)

Small silicon water-proof gasket dimension(size:mm)




Big silicon water-proof gasket dimension(size:mm)




### **Detection Pattern & Optional Accessories**

# 1. HBIR29/NLC (Low-bay

HBIR29/NLC: Low-bay flat lens detection pattern for single person @  $Ta = 20^{\circ}C$ (Recommended ceiling mount installation height 2.5m-6m)





Mount height	Tangential (A)	Radial (B)
2.5m	$\max 50\text{m}^2 (\varnothing = 8\text{m})$	$\max 13m^2 (\emptyset = 4m)$
3m	$\max 64m^2 (\emptyset = 9m)$	$\max 13m^2 (\emptyset = 4m)$
4m	$\max 38m^2 (\emptyset = 7m)$	$\max 13m^2 (\emptyset = 4m)$
5m	$\max 38m^2 (\emptyset = 7m)$	$\max 13m^2 (\emptyset = 4m)$
6m	$\max 38m^2 (\emptyset = 7m)$	$\max 13m^2 (\emptyset = 4m)$









Valid Range
















Blind Option 2 --- 180° Detection


# 2. HBIR29/NLC/R (Reinforced Low-bay)



# HBIR29/NLC/R: Low-bay convex lens detection pattern for single person @ Ta = 20°C

# (Recommended ceiling mount installation height 2.5m-6m)





Mount height	Tangential (A)	Radial (B)
2.5m	$\max 79\text{m}^2(\varnothing = 10\text{m})$	$\max 20m^2 (\emptyset = 5m)$
3m	$\max 79\text{m}^2 (\varnothing = 10\text{m})$	$\max 20m^2 (\emptyset = 5m)$
4m	$\max 64m^2 (\emptyset = 9m)$	$\max 20m^2 (\emptyset = 5m)$
5m	$\max 50m^2 (\emptyset = 8m)$	$\max 20m^2 (\emptyset = 5m)$
6m	$\max 50m^2 (\emptyset = 8m)$	$\max 20m^2 (\emptyset = 5m)$


Optional Accessory -- Ceiling/Surface Mount Box: HAO9











Optional Accessory --- Blind Insert for Blocking Certain Detection Angles









Blind Option 1 --- Aisle Detection

Blind Option 2 --- 180° Detection


Subject to change without notice.


Edition: 11 Mar. 2025 Ver. AO

# 3. HBIR29/NLC/H (High-bay)



# HBIR29/NLC/H: High-bay lens detection pattern for forklift @ Ta = 20°C (Recommended ceiling mount installation height 10m-15m)






Mount height	Tangential (A)	Radial (B)
1 Om	$max 380m^2 (\emptyset = 22m)$	$\max 201 m^2 (\emptyset = 16m)$
11m	$\max 452 m^2 (\emptyset = 24 m)$	$\max 201 \mathrm{m}^2 (\emptyset = 16 \mathrm{m})$
12m	$\max 452 m^2 (\emptyset = 24 m)$	$\max 201 m^2 (\emptyset = 16m)$
13m	$\max 452 m^2 (\emptyset = 24 m)$	$\max 177 m^2 (\emptyset = 15 m)$
14m	$\max 452 m^2 (\emptyset = 24 m)$	$\max 133m^2 (\varnothing = 13m)$
15m	$\max 452m^2 (\emptyset = 24m)$	$max 113m^2 (\emptyset = 12m)$



# HBIR29/NLC/H: High-bay lens detection pattern for single person @ Ta = 20°C (Recommended ceiling mount installation height 2.5m-12m)

A: Tangential movement





Mount height	Tangential (A)	Radial (B)
2.5m	$\max 50 \text{m}^2 (\emptyset = 8 \text{m})$	$\max 7m^2 (\emptyset = 3m)$
6m	$max 104m^2 (\emptyset = 11.5m)$	$\max 7m^2 (\emptyset = 3m)$
8m	$max 154m^2 (\emptyset = 14m)$	$\max 7m^2 (\emptyset = 3m)$
1 Om	$max 227m^2 (\emptyset = 17m)$	$\max 7m^2 (\emptyset = 3m)$
1 l m	$\max 269 \text{m}^2 (\emptyset = 18.5 \text{m})$	$\max 7m^2 (\emptyset = 3m)$
12m	$max 314m^2 (\emptyset = 20m)$	$\max 7m^2 (\emptyset = 3m)$






















Blind Option 2 --- 180° Detection

Subject to change without notice.

Edition: 11 Mar. 2025


Ver. AO


Page 6/8

# 4. HBIR29/NLC/RH (Reinforced High-bay with 3-Pyro)



# HBIR29/NLC/RH: Reinforced high-bay lens detection pattern for for forklift @ Ta = 20°C (Recommended ceiling mount installation height 10m-20m)







Mount height	Tangential (A)	Radial (B)
1 Om	max 346m² (Ø = 21m)	$max 177m^2 (\emptyset = 15m)$
1 1 m	$max 660m^2 (\emptyset = 29m)$	$max 177m^2 (\emptyset = 15m)$
12m	$max 907m^2 (\emptyset = 34m)$	$\max 154 \text{m}^2 (\emptyset = 14 \text{m})$
13m	$\max 962m^2 (\emptyset = 35m)$	$\max 154 m^2 (\emptyset = 14 m)$
14m	$\max 1075 \text{m}^2 (\emptyset = 37 \text{m})$	$max 113m^2 (\emptyset = 12m)$
1.5m	$max 1256m^2 (\emptyset = 40m)$	$max 113m^2 (\emptyset = 12m)$
20m	$max 707m^2 (\emptyset = 30m)$	$max 113m^2 (\emptyset = 12m)$



# HBIR29/NLC/RH: Reinforced high-bay lens detection pattern for single person @ Ta = 20°C (Recommended ceiling mount installation height 2.5m-12m)





Mount height	Tangential (A)	Radial (B)
2.5m	$\max 38m^2 (\emptyset = 7m)$	$\max 7m^2 (\emptyset = 3m)$
6m	$max 154m^2 (\emptyset = 14m)$	$\max 7m^2 (\emptyset = 3m)$
8m	$max 314m^2 (\emptyset = 20m)$	$\max 7m^2 (\emptyset = 3m)$
1 Om	$\max 531 \mathrm{m}^2 (\emptyset = 26 \mathrm{m})$	$\max 13m^2 (\emptyset = 4m)$
11m	$\max 615 m^2 (\emptyset = 28 m)$	$\max 13m^2 (\emptyset = 4m)$
12m	$\max 707 \text{m}^2 (\emptyset = 30 \text{m})$	$\max 13m^2 (\emptyset = 4m)$


#### Optional Accessory --- Ceilina/Surface Mount Box: HA09












Subject to change without notice.

#### Mesh Factory Reset

The device HBIR29/NLC can be reset by placing a strong magnet (e.g. N38 neodymium magnet, d=10mm\*h=4mm) near the sensor lens for 5 seconds. Once the factory reset is done successfully, the luminaire flashes and then permanent on, then the device is being able to be re-commissioned by SILVAIR app.

#### To Reprovision

Place a strong magnet on the site of the Reset/Hall effect sensor (see diagram 4 below). To trigger the reset the magnet must be held in position for 5 seconds.



Note: When change the lens part of HBIR29/NLC, please kindly make sure that the lens fits the right location, where the "Reset dot" and "BLE dot" matches with the physical location on the PCB.

Status LED blinking Sequence		
HBIR29/NLC Unprovisioned	30ms ON	300ms OFF
HBIR29/NLC Provisioned	15ms ON	2,000ms OFF
Factory reset	500ms ON	1,000ms OFF
Factory reset (initial burst)	100ms ON	1,000ms OFF
MESH package received	30ms ON	50ms OFF
Attention (from network)	500ms ON	500ms OFF

# Additional Information / Documents

- 1. To learn more about detailed product features/functions, please kindly refer to https://hytronik.com/product/hbir29-nlc
- 2. Regarding precautions for Bluetooth product installation and operation, please kindly refer to https://hytronik.com/service/downloads (Bluetooth Products Precautions for Product linstallation and Operation)
- 3. Regarding precautions for PIR sensors installation and operation, please kindly refer to https://hytronik.com/service/downloads (PIR Sensors Precautions for Product Installation and Operation)
- 4. Data sheet is subject to change without notice. Please always refer to the most recent release on https://hytronik.com/products/motion-daylight-sensors
- 5. Regarding Hytronik standard guarantee policy, please kindly refer to https://hytronik.com/service/downloads (Guarantee Conditions document)

Edition: 11 Mar. 2025 Ver. AO Page 8/8