# **Installation and Instruction Manual**



PIR Standalone Motion Sensor with ❸ Bluetooth® 5.0 SIG Mesh
Two DALI Channels Output


HBIR32

# 1. Technical Specifications

Operation frequency	2.4 GHz - 2.483 GHz
Transmission power	4 dBm
Range (Typical indoor)	10~30m
Protocol	Bluetooth® 5.0 SIG Mesh
Operating voltage	220~240VAC 50/60Hz
Stand-by power	<1W
DALI Channel 1	Max. 50mA
DALI Channel 2	Max. 30mA
Sensor principle	PIR detection
Detection range (Max.)*	Installation Height: 6m
	Detection Range (Ø) :9m
Detection angle	360°
Operation temperature	Ta:-20°C~+50°C
IP rating	IP20/IP54


# 2. Download the App

Free App for set-up and commissioning




## 3. Installation

Mechanical Structure & Dimensions



- 1. Ceiling (drill hole φ66~68mm)
- 2. Carefully prise off the cable clamps.
- 3. Make connections to the pluggable terminal blocks.
- Insert plug connectors and secure using the provided cable clamps, then clip terminal covers to the base.
- 5. Fit detection blind (if required) and desired lens.
- 6. Clip fascia to body.
- 7. Bend back springs and insert into ceiling.

# 4. Wiring Diagram



-This product should be installed by a qualified electrician.

# Wire Preparation





Pluggable screw terminal. It is recommended to make connections to the terminal before fitting to the sensor.

- 1. 200 metres (total) max. for 1mm<sup>2</sup> CSA (Ta = 50°C)
- 2. 300 metres (total) max. for 1.5mm² CSA (Ta = 50°C)

HYTRONIK



Subject to change without notice.

WWW.HYTRONIK.COM

# 5. Detection Pattern & Optional Accessories

### HBIR32 (Low-bay) **HBIR32**: Low-bay flat lens detection pattern for **single person** @ $Ta = 20^{\circ}C$ (Recommended ceiling mount installation height 2.5m-6m) A: Tangential movement B: Radial movement Tangential (A) Radial (B) Mount height $\max 50m^2 (\emptyset = 8m)$ $\max 13m^2 (\emptyset = 4m)$ 2.5m 3m $\max 64m^2 (\emptyset = 9m)$ $\max 13m^2 (\emptyset = 4m)$ $\max 13m^2 (\emptyset = 4m)$ 4m $\max 38m^2 (\emptyset = 7m)$ $\max 13m^2 (\emptyset = 4m)$ 5m $\max 38m^2 (\emptyset = 7m)$ $\max 13m^2 (\emptyset = 4m)$ 6m $\max 38m^2 (\emptyset = 7m)$

# Optional Accessory --- Ceiling/Surface Metal Mount Box: HA09/W. HA09/B. HA09/G











Optional Accessory --- Blind Insert for Blocking Certain Detection Angles










Blind Option 2 --- 180° Detection


Small silicon water-proof gasket dimension(size:mm)



Big silicon water-proof gasket dimension(size:mm)







# HYTRONIK

# Placement Guide and Typical Range

Smart Phone to Device Range



The smart device with the App installed will have a typical range of 10m, but varies from device to device. During commissioning, the installer will need to be in range of the devices when searching for devices to add to the network.

Once the devices have been added to the network via the App, the devices will start communicating within the wireless mesh. This means that once the network is complete, all devices are accessible from the smart device when in a 20m range of a single point.

# 6. Dimming Interface Operation Notes

The provided Switch-Dim interface allows for a simple dimming method using commercially available non-latching (momentary) wall switches. Detailed Push switch configurations can be set on Koolmesh app.

Switch Function	Action	Descriptions	
	Short press (<1 second)  * Short press has to be longer than 0.1s, or it will be invalid.	- Turn on/off - Recall a scene - Turn on only - Quit manual mode - Turn off only - Do nothing	
Push switch	Double push	- Turn on only - Quit manual mode - Turn off only - Do nothing - Recall a scene	
	Long press (≥1 second)	- Dimming - Colour tuning - Do nothing	
Sensor-link (VFC signal only)	/	<ul> <li>Upgrade a normal on/off motion sensor to a Bluetooth controlled motion sensor</li> </ul>	
* S Emergency Self-Test Function	Short press (<1 second)  * Short press has to be longer than 0.1s, or it will be invalid.	- Start Self test (Monthly) - Start Self test (Annually - Stop Self test - Invalid	<i>(</i> )
	Long press (≥1 second)	- Start Self test (Monthly) - Start Self test (Annually - Stop Self test - Invalid	/)
Fire Alarm (VFC signal only)	Refer to <b>Koolmesh</b> * App User Manual V2.1	- Able to connect the Fire Alarm system - Once the fire alarm system is triggered, all the lum controlled by the Push Switch will enter the preset (normally it's full on), after the fire alarm system gives the signal, all the luminaries controlled by this Push Switch will back to normal status.	scene ending

## 7. Additional Information / Documents

- 1.To learn more about detailed product features/functions, please refer to www.hytronik.com/download ->knowledge ->Introduction of App Scenes and Product Functions
- 2. Regarding precautions for Bluetooth product installation and operation, please kindly refer to www.hytronik.com ->download/knowledge ->Bluetooth Products Precautions for Product Installation and Operation
- 3. Data sheet is subject to change without notice. Please always refer to the most recent release on www.hytronik.com/products/bluetooth technology ->Bluetooth Sensors
- 4. Regarding Hytronik standard guarantee policy, please refer to www.hytronik.com/download ->knowledge ->Hytronik Standard Guarantee Policy

Subject to change without notice.