IP65 HF Zhaga book 18 Standard Motion Sensor

SAM15 (High-Bay)
DALI-2 output

Product Description

SAM15 is a Zhaga book 18 standard HF motion sensor with DALI-2 output (40mA DALI power supply built-in), which enables lighting designers/manufacturers to freely connect to luminaires. All sensor parameters can be programmed through remote controller HRC-11, like adjusting sensitivity, time, lux level, and brightness settings. Designed with a sturdy IP65 structure, HIR15 is perfect for high-bay applications, accommodating installations of up to 12m in height, making it ideal for outdoor lighting like streetlights.





Hardware Features

40mA DALI-2 Broadcast output

Zhaga Book 18 standard

IP IP65 design

Robust HF antenna design wireless interference

High-bay (up to 12m height)

🗦 5-year warranty

Technical Specifications


Input & Output Characteristics		
Operating voltage	24VDC	
Stand-by power	<1W	
Output	l guaranteed: 32mA l max: 40 mA U rated: 15VDC	
Lux range	0-1000Lux	


Environment	
Operation temperature	Ta: -20°C ~ +50°C
Storage temperature	-40°C~+70°C
Relative humidity	10~90%
IP rating	IP65
Insulation	Class II

Sensor Data	
Sensor principle	High Frequency (microwave)
Detection range*	Max installation height: 12m Max detection range: 14m
Detection angle	360°


^{*} The detection range is heavily influenced by sensor placement (angle) and different walking paces. It may be reduced under certain conditions.

EN61547, EN50015
EN61347-1 EN61347-2-11
CE, UKCA
EN300440,EN301489-1/-3
EN50663
RoHs, Reach
IEC62386-101/103, Part 351
Single master, Type D






Wiring Diagram 3



Detection Range



Ceiling mounted detection pattern (m)


Sensitivity						
Height (m)	100%	75%	50%	30%	10%	
	Diameter (Ø:m)					
12	11	9	6	none	none	
8	12	10	6	2	none	
5	13	11	7	5	2	
3	14	12	8	6	5	

Robust HF Sensors Design --- Anti-interference Technology




Hytronik's microwave motion sensor uses 5.8GHz high frequency (HF) antenna in the product design. With the increasing density of wireless environments such as 5G GSM tower and 5G Wi-Fi coverage, this has created extra challenges for sensor's operation because the air is shared by all kinds of wireless signals, and transmissions from any device at the similar frequency could potentially cause interference. The effects of interference which can be noticed by users are usually false triggering of sensors (turning on/off erratically), or lights staying on even after hold time etc.

To get around such tough environment, Hytronik has developed a new series of robust HF modules, designed to be loaded with our own special sophiscated software algorithms. These robust HF modules can withstand different types of wireless interferences in the real application. We believe this is the ultimate solution towards demanding installation environments in the future.




Settings (Remote Control HRC-11)



HRC-11

ON OFF	Press button "ON/OFF" to select permanent ON or permanent OFF mode. * Press button "AUTO"/ "RESET" to exit this mode.
RESET	Press button "RESET", perform the latest DIP Switch/Rotary Switch settings. The default settings are: Auto mode; DALI Master mode; Detection range 100%; Hold-time 5min; Daylight sensor disable; Stand-by time10min; Stand-by dimming level 20%; Maximum Brightness & Color turning; LED indication off; Lux off activated; HFdetection mode.
Shift	Press button "Shift", the LED on the top left corner is on to indicate mode selection. All values / settings in RED are valid for 20 seconds.
AUTO	Press button "AUTO" to initiate automatic mode. The sensor starts working and all settings remain as before the light is switched ON/OFF;
SEMI-AUTO	This key is not appliable on this product.
Power 100% 80%	Press buttons in zone "Power out" to select the light output at 80% (at initial 10,000 hours) or 100%.
Sensor off Twilight	1. Press button "Shift", the red LED on. 2. Press button "Sensor off", the function of movement detection is disabled, the function of photocell is also disabled. OR Press button "Twilight", the function of movement detection is disabled, but the function of photocell is still working, and the product becomes a pure dusk/ dawn To exit from "Sensor off"/"Twilight" mode, press button "AUTO"/"SEMI-AUTO"/"RESET".
•••	Press these two buttons to adjust the light output brightness and set a new target lux level. The daylight sensor can measure ambient daylight level and ignore the LED light, so as to calculate how much artificial light is needed to maintain the target lux level.
CCT+	1. Press button "Shift", tthe red LED on. 2. Press "CCT+" or "CCT-" button to adjust colour turning.
Start Memory Apply	 Press button "Start" to program. Select the buttons in "Detection range", "Daylight threshold", "Hold-time", "Stand-by time", "Stand-by dimming level" to set all parameters. Press button "Memory" to save all the settings programmed in the remote control. Press button "Apply" to set the settings to each sensor unit(s). For example, to set detection range 100%, daylight threshold Disable, hold-time 5min, stand-by time +∞, stand-by dimming level 30%, the steps should be: Press button "Start", button "100%", "Disable", "Shift", "5min", "Shift", "+∞", "30%", "Memory". By pointing to the sensor unit(s) and pressing "Apply", all settings are passed on the sensor(s).
- Lux off	The "Lux off" function is activated as default. When the ambient lux level exceeds the target level continuously for more than 5 minutes, the lights will be turned off. In AUTO /SEMI-AUTO/Twilight modes, to disable "Lux off": 1. Press "Shift" button first, the red LED on. 2. Press "Lux off" button, the "Lux Off" function will be deactivated. The lights will not turn off even when the ambient lux level exceeds the target lux level but will dim down the brightness to the stand-by time level. For Sensor LED indicator references: 1. Fast flash 1s, "Lux off" function activated.
Exp 1 Exp 2	2.Remains on 2s, "Lux off" function deactivated. "Exp" refer to Expansion, these two buttons are reserved functions and pending future development.



Additional Information / Documents

1. Regarding precautions for microwave sensor installation and operation, please kindly refer to
www.hytronik.com/download →knowledge →Microwave Sensors - Precautions for Product Installation and Operation

2. Regarding Hytronik standard guarantee policy, please refer to	
www.hytronik.com/download →knowledge →Hytronik Standard Guarantee	Policy